



CATALOG NO.	AZMS NO.	"L" (in.)	"F" (in.)	"E" (in.)	"C" (in.)	WT. (lbs.)	# FRAMES
UC2L2T036AP	UD12-036	36.00	29.00	3.50	26.00	172	2
UC2L2T048AP	UD12-048	48.00	29.00	9.50	26.00	188	
UC2L2T060AP	UD12-060	60.00	43.00	8.50	40.00	204	
UC2L2T072AP	UD12-072	72.00	57.00	7.50	54.00	220	
UC2L2T084AP	UD12-084	84.00	57.00	13.50	54.00	292	
UC2L2T096AP	UD12-096	96.00	83.00	6.50	40.00	308	3
UC2L2T108AP	UD12-108	108.00	83.00	12.50	40.00	324	
UC2L2T120AP	UD12-120	120.00	111.00	4.50	54.00	340	
UC2L2T132AP	UD12-132	132.00	111.00	10.50	54.00	412	
UC2L2T144AP	UD12-144	144.00	111.00	16.50	54.00	435	
UC2L2T156AP	UD12-156	156.00	147.00	4.50	48.00	451	4
UC2L2T168AP	UD12-168	168.00	147.00	10.50	48.00	524	
UC2L2T180AP	UD12-180	180.00	165.00	7.50	54.00	540	
UC2L2T194AP	UD12-192	192.00	165.00	13.50	54.00	556	
UC2L2T204AP	UD12-204	204.00	195.00	4.50	48.00	572	
UC2L2T216AP	UD12-216	216.00	195.00	10.50	48.00	644	5
UC2L2T232AP	UD12-228	228.00	219.00	4.50	54.00	660	
UC2L2T240AP	UD12-240	240.00	219.00	10.50	54.00	676	

RAIL OPTIONS, IDENTIFIED BY CATALOG NO. SUFFIX:
 AP - 2 PAINTED RAILS PER TIER (STANDARD)
 A3RP - 3 PAINTED RAILS PER TIER

TITLE: RACK, UBC ZONE 2L, 2 TIER

EnerSys
 Power/Full Solutions™

RESERVE POWER
 READING, PA. 19605

THIS DRAWING AND THE INFORMATION CONTAINED THEREON IS SUBMITTED CONFIDENTIALLY AND IS THE PROPERTY OF EnerSys. USE, REPRODUCTION OR DISCLOSURE OF THE CONTENT OF THIS DRAWING OR ANY PORTION THEREOF FOR ANY PURPOSE MUST BE APPROVED IN WRITING BY EnerSys.

BATTERY: CA, CC, CX	CODE: UD12	REF.: N/A
RACK FAMILY: UC2L2TxxxAP		REV. A
DO NOT SCALE DRAWING		DATE: 06/11/2009